

ANALYSIS REPORT

Kamstrup A/S
Industrivej 28
8660 Skanderborg

Case name: **Kamstrup - Flow bench ZN1 1020/1021**
Number of samples: 1
Samples received: 17-08-2026
Report date: 20-08-2026
Report no.: 145086 ~

Sampling start:	17-08-2026 kl.08:03	Laboratory no.:	DV26260141-001
Sampler:	Højvang/fko	Sample ID:	ZN1 1020/1021
Analysis period:	17-08-2026 to 20-08-2026	Packaging:	OK
Sampling point:	Kamstrup industrivej 28 / 51.;	Purpose:	Operational control
Sample type:	Process water (analyzed as drinking water)	Scope:	Microbiological control
Withdrawal method:	Random sample		
Sampling method:	ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021		

Parameter	Result	Unit	Min / Max.	DL	References	+/-
Temperature	21,2	°C		0	SM 2550:2005, Felt	s
Pseudomonas aeruginosa	0	CFU/100 mL	/ 0	0	ISO 16266:2008+MM0014^	d 0,24 (lg)
Coliform bacteria	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)
Escherichia coli (E.coli)	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)

Exceedances: No exceedances, cf. the min. / Max. Values specified in the report

Deviations / comments for this test: None

Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.

Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.

Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.

Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.

Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

Approved by:



Heidi Jensen
Laborant

The report will be sent by email to:

vandanalsedk@kamstrup.com - Vandanalyser

Report status: Final

Appendices for this report:

None

Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

* Not accredited.

Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number.

ANALYSIS REPORT

Kamstrup A/S
Industrivej 28
8660 Skanderborg

Case name: **Kamstrup - Flow bench ZN1 1022/1023**
 Number of samples: 1
 Samples received: 17-08-2026
 Report date: 20-08-2026
 Report no.: 145088 ~

Sampling start:	17-08-2026 kl.08:07	Laboratory no.:	DV26260142-001
Sampler:	Højvang/fko	Sample ID:	ZN1 1022/1023
Analysis period:	17-08-2026 to 20-08-2026	Packaging:	OK
Sampling point:	Kamstrup industrivej 28 / 51.;	Purpose:	Operational control
Sample type:	Process water (analyzed as drinking water)	Scope:	Microbiological control
Withdrawal method:	Random sample		
Sampling method:	ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021		

Parameter	Result	Unit	Min / Max.	DL	References	+/-
Temperature	16,5	°C		0	SM 2550:2005, Felt	s
Pseudomonas aeruginosa	0	CFU/100 mL	/ 0	0	ISO 16266:2008+MM0014^	d 0,24 (lg)
Coliform bacteria	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)
Escherichia coli (E.coli)	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)

Exceedances: No exceedances, cf. the min. / Max. Values specified in the report

Deviations / comments for this test: None

Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.
 Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.
 Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.
 Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.
 Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

Approved by:



Heidi Jensen
 Laborant

The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Appendices for this report:

None

Report status: Final

Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.
 * Not accredited.
 # Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.
 ^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.
 ~ This is a translation of the Danish report with the same report number .

ANALYSIS REPORT

Kamstrup A/S
Industrivej 28
8660 Skanderborg

Case name: **Kamstrup - Flow bench ZN1 1024/1025**
Number of samples: 1
Samples received: 17-08-2026
Report date: 20-08-2026
Report no.: 145091 ~

Sampling start:	17-08-2026 kl.08:10	Laboratory no.:	DV26260143-001
Sampler:	Højvang/fko	Sample ID:	ZN1 1024/1025
Analysis period:	17-08-2026 to 20-08-2026	Packaging:	OK
Sampling point:	Kamstrup industrivej 28 / 51.;	Purpose:	Operational control
Sample type:	Process water (analyzed as drinking water)	Scope:	Microbiological control
Withdrawal method:	Random sample		
Sampling method:	ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021		

Parameter	Result	Unit	Min / Max.	DL	References	+/-
Temperature	20,2	°C		0	SM 2550:2005, Felt	s
Pseudomonas aeruginosa	0	CFU/100 mL	/ 0	0	ISO 16266:2008+MM0014^	d 0,24 (lg)
Coliform bacteria	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)
Escherichia coli (E.coli)	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)

Exceedances: No exceedances, cf. the min. / Max. Values specified in the report

Deviations / comments for this test: None

Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.

Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.

Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.

Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.

Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

Approved by:



Heidi Jensen
Laborant

The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Report status: Final

Appendices for this report:

None

Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

* Not accredited.

Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number.

ANALYSIS REPORT

Kamstrup A/S
Industrivej 28
8660 Skanderborg

Case name: **Kamstrup - Flow bench ZN1 1026/1027**
Number of samples: 1
Samples received: 17-08-2026
Report date: 20-08-2026
Report no.: 145094 ~

Sampling start:	17-08-2026 kl.08:13	Laboratory no.:	DV26260144-001
Sampler:	Højvang/fko	Sample ID:	ZN1 1026/1027
Analysis period:	17-08-2026 to 20-08-2026	Packaging:	OK
Sampling point:	Kamstrup industrivej 28 / 51.;	Purpose:	Operational control
Sample type:	Process water (analyzed as drinking water)	Scope:	Microbiological control
Withdrawal method:	Random sample		
Sampling method:	ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021		

Parameter	Result	Unit	Min / Max.	DL	References	+/-
Temperature	18,9	°C		0	SM 2550:2005, Felt	s
Pseudomonas aeruginosa	0	CFU/100 mL	/ 0	0	ISO 16266:2008+MM0014^	d 0,24 (lg)
Coliform bacteria	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)
Escherichia coli (E.coli)	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)

Exceedances: No exceedances, cf. the min. / Max. Values specified in the report

Deviations / comments for this test: None

Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.
Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.
Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.
Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.
Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

Approved by:



Heidi Jensen
Laborant

The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Appendices for this report:

None

Report status: Final

Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.
* Not accredited.
Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.
^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.
~ This is a translation of the Danish report with the same report number.

ANALYSIS REPORT

Kamstrup A/S
Industrivej 28
8660 Skanderborg

Case name: **Kamstrup - Flow bench 1032**
 Number of samples: 1
 Samples received: 17-08-2026
 Report date: 20-08-2026
 Report no.: 145096 ~

Sampling start:	17-08-2026 kl.08:20	Laboratory no.:	DV26260145-001
Sampler:	Højvang/fko	Sample ID:	1032
Analysis period:	17-08-2026 to 20-08-2026	Packaging:	OK
Sampling point:	Kamstrup industrivej 28 / 51.;	Purpose:	Operational control
Sample type:	Process water (analyzed as drinking water)	Scope:	Microbiological control
Withdrawal method:	Random sample		
Sampling method:	ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021		

Parameter	Result	Unit	Min / Max.	DL	References	+/-
Temperature	21,0	°C		0	SM 2550:2005, Felt	s
Pseudomonas aeruginosa	0	CFU/100 mL	/ 0	0	ISO 16266:2008+MM0014^	d 0,24 (lg)
Coliform bacteria	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)
Escherichia coli (E.coli)	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)

Exceedances: No exceedances, cf. the min. / Max. Values specified in the report

Deviations / comments for this test: None

Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.
 Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.
 Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.
 Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.
 Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

Approved by:



Heidi Jensen
 Laborant

The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Appendices for this report:

None

Report status: Final

Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.
 * Not accredited.
 # Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.
 ^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.
 ~ This is a translation of the Danish report with the same report number .

ANALYSIS REPORT

Kamstrup A/S
Industrivej 28
8660 Skanderborg

Case name: **Kamstrup - Flow bench 1031**
Number of samples: 1
Samples received: 17-08-2026
Report date: 20-08-2026
Report no.: 145098 ~

Sampling start:	17-08-2026 kl.08:24	Laboratory no.:	DV26260146-001
Sampler:	Højvang/fko	Sample ID:	1031
Analysis period:	17-08-2026 to 20-08-2026	Packaging:	OK
Sampling point:	Kamstrup industrivej 28 / 51.;	Purpose:	Operational control
Sample type:	Process water (analyzed as drinking water)	Scope:	Microbiological control
Withdrawal method:	Random sample		
Sampling method:	ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021		

Parameter	Result	Unit	Min / Max.	DL	References	+/-
Temperature	20,4	°C		0	SM 2550:2005, Felt	s
Pseudomonas aeruginosa	0	CFU/100 mL	/ 0	0	ISO 16266:2008+MM0014^	d 0,24 (lg)
Coliform bacteria	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)
Escherichia coli (E.coli)	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)

Exceedances: No exceedances, cf. the min. / Max. Values specified in the report

Deviations / comments for this test: None

Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.

Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.

Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.

Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.

Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

Approved by:



Heidi Jensen
Laborant

The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Report status: Final

Appendices for this report:

None

Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

* Not accredited.

Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number .

ANALYSIS REPORT

Kamstrup A/S
Industrivej 28
8660 Skanderborg

Case name: **Kamstrup - Flow bench 1030**
 Number of samples: 1
 Samples received: 17-08-2026
 Report date: 20-08-2026
 Report no.: 145103 ~

Sampling start:	17-08-2026 kl.08:17	Laboratory no.:	DV26260148-001
Sampler:	Højvang/fko	Sample ID:	1030
Analysis period:	17-08-2026 to 20-08-2026	Packaging:	OK
Sampling point:	Kamstrup industrivej 28 / 51.;	Purpose:	Operational control
Sample type:	Process water (analyzed as drinking water)	Scope:	Microbiological control
Withdrawal method:	Random sample		
Sampling method:	ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021		

Parameter	Result	Unit	Min / Max.	DL	References	+/-
Temperature	20,4	°C		0	SM 2550:2005, Felt	s
Pseudomonas aeruginosa	0	CFU/100 mL	/ 0	0	ISO 16266:2008+MM0014^	d 0,24 (lg)
Coliform bacteria	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)
Escherichia coli (E.coli)	0	MPN/100 mL	/ < 0	0	DS/EN ISO 9308-2:2014+MM0001^	d 0,25 (lg)

Exceedances: No exceedances, cf. the min. / Max. Values specified in the report

Deviations / comments for this test: None

Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.
 Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.
 Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.
 Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.
 Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

Approved by:



Heidi Jensen
 Laborant

The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Appendices for this report:

None

Report status: Final

Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

* Not accredited.

Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number .