

# ANALYSIS REPORT

**Kamstrup A/S**  
**Industrivej 28**  
**8660 Skanderborg**

Case name: **Kamstrup - Flow bench ZN1 1020/1021**  
 Number of samples: 1  
 Samples received: 14-09-2026  
 Report date: 17-09-2026  
 Report no.: 148321 ~

|                    |                                                               |                   |                         |
|--------------------|---------------------------------------------------------------|-------------------|-------------------------|
| Sampling start:    | 14-09-2026 kl.07:53                                           | Laboratory no.:   | DV26290305-001          |
| Sampler:           | Højvang/fko                                                   | <b>Sample ID:</b> | <b>ZN1 1020/1021</b>    |
| Analysis period:   | 14-09-2026 to 17-09-2026                                      | Packaging:        | OK                      |
| Sampling point:    | <b>Kamstrup industrivej 28 / 51.;</b>                         | Purpose:          | Operational control     |
| Sample type:       | <b>Process water (analyzed as drinking water)</b>             | Scope:            | Microbiological control |
| Withdrawal method: | Random sample                                                 |                   |                         |
| Sampling method:   | ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021 |                   |                         |

| Parameter                 | Result | Unit       | Min / Max. | DL | References                    | +/-         |
|---------------------------|--------|------------|------------|----|-------------------------------|-------------|
| Temperature               | 17,4   | °C         |            | 0  | SM 2550:2005, Felt            | s           |
| Pseudomonas aeruginosa    | 0      | CFU/100 mL | / 0        | 0  | ISO 16266:2008+MM0014^        | d 0,24 (lg) |
| Coliform bacteria         | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |
| Escherichia coli (E.coli) | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |

**Exceedances:** No exceedances, cf. the min. / Max. Values specified in the report

**Deviations / comments for this test:** None

## Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.  
 Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.  
 Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.  
 Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.  
 Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

## Approved by:



Heidi Jensen  
 Laborant

## The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Report status: Final

## Appendices for this report:

Rekvisation - DV26290305.pdf-0003039257.pdf

## Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

\* Not accredited.

# Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number .

# ANALYSIS REPORT

**Kamstrup A/S**  
**Industrivej 28**  
**8660 Skanderborg**

Case name: **Kamstrup - Flow bench ZN1 1022/1023**  
Number of samples: 1  
Samples received: 14-09-2026  
Report date: 17-09-2026  
Report no.: 148329 ~

|                    |                                                               |                   |                         |
|--------------------|---------------------------------------------------------------|-------------------|-------------------------|
| Sampling start:    | 14-09-2026 kl.07:57                                           | Laboratory no.:   | DV26290306-001          |
| Sampler:           | Højvang/fko                                                   | <b>Sample ID:</b> | <b>ZN1 1022/1023</b>    |
| Analysis period:   | 14-09-2026 to 17-09-2026                                      | Packaging:        | OK                      |
| Sampling point:    | <b>Kamstrup industrivej 28 / 51.;</b>                         | Purpose:          | Operational control     |
| Sample type:       | <b>Process water (analyzed as drinking water)</b>             | Scope:            | Microbiological control |
| Withdrawal method: | Random sample                                                 |                   |                         |
| Sampling method:   | ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021 |                   |                         |

| Parameter                 | Result | Unit       | Min / Max. | DL | References                    | +/-         |
|---------------------------|--------|------------|------------|----|-------------------------------|-------------|
| Temperature               | 17,9   | °C         |            | 0  | SM 2550:2005, Felt            | s           |
| Pseudomonas aeruginosa    | 0      | CFU/100 mL | / 0        | 0  | ISO 16266:2008+MM0014^        | d 0,24 (lg) |
| Coliform bacteria         | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |
| Escherichia coli (E.coli) | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |

**Exceedances:** No exceedances, cf. the min. / Max. Values specified in the report

**Deviations / comments for this test:** None

## Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.  
Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.  
Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.  
Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.  
Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

## Approved by:



Heidi Jensen  
Laborant

## The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Report status: Final

## Appendices for this report:

None

## Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.  
\* Not accredited.  
# Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.  
^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.  
~ This is a translation of the Danish report with the same report number.

## ANALYSIS REPORT

Kamstrup A/S  
Industrivej 28  
8660 Skanderborg

Case name: **Kamstrup - Flow bench ZN1 1024/1025**  
Number of samples: 1  
Samples received: 14-09-2026  
Report date: 17-09-2026  
Report no.: 148341 ~

|                    |                                                               |                   |                         |
|--------------------|---------------------------------------------------------------|-------------------|-------------------------|
| Sampling start:    | 14-09-2026 kl.08:01                                           | Laboratory no.:   | DV26290307-001          |
| Sampler:           | Højvang/fko                                                   | <b>Sample ID:</b> | <b>ZN1 1024/1025</b>    |
| Analysis period:   | 14-09-2026 to 17-09-2026                                      | Packaging:        | OK                      |
| Sampling point:    | <b>Kamstrup industrivej 28 / 51.;</b>                         | Purpose:          | Operational control     |
| Sample type:       | <b>Process water (analyzed as drinking water)</b>             | Scope:            | Microbiological control |
| Withdrawal method: | Random sample                                                 |                   |                         |
| Sampling method:   | ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021 |                   |                         |

| Parameter                 | Result | Unit       | Min / Max. | DL | References                    | +/-         |
|---------------------------|--------|------------|------------|----|-------------------------------|-------------|
| Temperature               | 18,6   | °C         |            | 0  | SM 2550:2005, Felt            | s           |
| Pseudomonas aeruginosa    | 0      | CFU/100 mL | / 0        | 0  | ISO 16266:2008+MM0014^        | d 0,24 (lg) |
| Coliform bacteria         | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |
| Escherichia coli (E.coli) | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |

**Exceedances:** No exceedances, cf. the min. / Max. Values specified in the report

**Deviations / comments for this test:** None

### Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.

Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.

Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.

Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.

Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

### Approved by:



Heidi Jensen  
Laborant

### The report will be sent by email to:

vandanalsedk@kamstrup.com - Vandanalyser

Report status: Final

### Appendices for this report:

None

### Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

\* Not accredited.

# Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number.

# ANALYSIS REPORT

**Kamstrup A/S**  
**Industrivej 28**  
**8660 Skanderborg**

Case name: **Kamstrup - Flow bench ZN1 1026/1027**  
 Number of samples: 1  
 Samples received: 14-09-2026  
 Report date: 17-09-2026  
 Report no.: 148344 ~

|                    |                                                               |                   |                         |
|--------------------|---------------------------------------------------------------|-------------------|-------------------------|
| Sampling start:    | 14-09-2026 kl.08:07                                           | Laboratory no.:   | DV26290308-001          |
| Sampler:           | Højvang/fko                                                   | <b>Sample ID:</b> | <b>ZN1 1026/1027</b>    |
| Analysis period:   | 14-09-2026 to 17-09-2026                                      | Packaging:        | OK                      |
| Sampling point:    | <b>Kamstrup industrivej 28 / 51.;</b>                         | Purpose:          | Operational control     |
| Sample type:       | <b>Process water (analyzed as drinking water)</b>             | Scope:            | Microbiological control |
| Withdrawal method: | Random sample                                                 |                   |                         |
| Sampling method:   | ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021 |                   |                         |

| Parameter                 | Result | Unit       | Min / Max. | DL | References                    | +/-         |
|---------------------------|--------|------------|------------|----|-------------------------------|-------------|
| Temperature               | 18,3   | °C         |            | 0  | SM 2550:2005, Felt            | s           |
| Pseudomonas aeruginosa    | 0      | CFU/100 mL | / 0        | 0  | ISO 16266:2008+MM0014^        | d 0,24 (lg) |
| Coliform bacteria         | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |
| Escherichia coli (E.coli) | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |

**Exceedances:** No exceedances, cf. the min. / Max. Values specified in the report

**Deviations / comments for this test:** None

## Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.  
 Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.  
 Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.  
 Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.  
 Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

## Approved by:



Heidi Jensen  
 Laborant

## The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

## Appendices for this report:

None

Report status: Final

## Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.  
 \* Not accredited.  
 # Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.  
 ^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.  
 ~ This is a translation of the Danish report with the same report number .

# ANALYSIS REPORT

**Kamstrup A/S**  
**Industrivej 28**  
**8660 Skanderborg**

Case name: **Kamstrup - Flow bench 1032**  
 Number of samples: 1  
 Samples received: 14-09-2026  
 Report date: 17-09-2026  
 Report no.: 148346 ~

|                    |                                                               |                   |                         |
|--------------------|---------------------------------------------------------------|-------------------|-------------------------|
| Sampling start:    | 14-09-2026 kl.08:15                                           | Laboratory no.:   | DV26290309-001          |
| Sampler:           | Højvang/fko                                                   | <b>Sample ID:</b> | <b>1032</b>             |
| Analysis period:   | 14-09-2026 to 17-09-2026                                      | Packaging:        | OK                      |
| Sampling point:    | <b>Kamstrup industrivej 28 / 51.;</b>                         | Purpose:          | Operational control     |
| Sample type:       | <b>Process water (analyzed as drinking water)</b>             | Scope:            | Microbiological control |
| Withdrawal method: | Random sample                                                 |                   |                         |
| Sampling method:   | ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021 |                   |                         |

| Parameter                 | Result | Unit       | Min / Max. | DL | References                    | +/-         |
|---------------------------|--------|------------|------------|----|-------------------------------|-------------|
| Temperature               | 20,6   | °C         |            | 0  | SM 2550:2005, Felt            | s           |
| Pseudomonas aeruginosa    | 0      | CFU/100 mL | / 0        | 0  | ISO 16266:2008+MM0014^        | d 0,24 (lg) |
| Coliform bacteria         | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |
| Escherichia coli (E.coli) | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |

**Exceedances:** No exceedances, cf. the min. / Max. Values specified in the report

**Deviations / comments for this test:** None

## Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.  
 Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.  
 Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.  
 Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.  
 Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

## Approved by:



Heidi Jensen  
 Laborant

## The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

## Appendices for this report:

None

Report status: Final

## Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

\* Not accredited.

# Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number .

## ANALYSIS REPORT

Kamstrup A/S  
Industrivej 28  
8660 Skanderborg

Case name: **Kamstrup - Flow bench 1031**  
Number of samples: 1  
Samples received: 14-09-2026  
Report date: 17-09-2026  
Report no.: 148348 ~

|                    |                                                               |                   |                         |
|--------------------|---------------------------------------------------------------|-------------------|-------------------------|
| Sampling start:    | 14-09-2026 kl.08:20                                           | Laboratory no.:   | DV26290310-001          |
| Sampler:           | Højvang/fko                                                   | <b>Sample ID:</b> | <b>1031</b>             |
| Analysis period:   | 14-09-2026 to 17-09-2026                                      | Packaging:        | OK                      |
| Sampling point:    | <b>Kamstrup industrivej 28 / 51.;</b>                         | Purpose:          | Operational control     |
| Sample type:       | <b>Process water (analyzed as drinking water)</b>             | Scope:            | Microbiological control |
| Withdrawal method: | Random sample                                                 |                   |                         |
| Sampling method:   | ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021 |                   |                         |

| Parameter                 | Result | Unit       | Min / Max. | DL | References                    | +/-         |
|---------------------------|--------|------------|------------|----|-------------------------------|-------------|
| Temperature               | 20,7   | °C         |            | 0  | SM 2550:2005, Felt            | s           |
| Pseudomonas aeruginosa    | 0      | CFU/100 mL | / 0        | 0  | ISO 16266:2008+MM0014^        | d 0,24 (lg) |
| Coliform bacteria         | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |
| Escherichia coli (E.coli) | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |

**Exceedances:** No exceedances, cf. the min. / Max. Values specified in the report

**Deviations / comments for this test:** None

### Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.

Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.

Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.

Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.

Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

### Approved by:



Heidi Jensen  
Laborant

### The report will be sent by email to:

vandanalsedk@kamstrup.com - Vandanalyser

### Appendices for this report:

None

Report status: Final

### Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

\* Not accredited.

# Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number.

# ANALYSIS REPORT

**Kamstrup A/S**  
**Industrivej 28**  
**8660 Skanderborg**

Case name: **Kamstrup - Flow bench 1030**  
Number of samples: 1  
Samples received: 14-09-2026  
Report date: 17-09-2026  
Report no.: 148350 ~

|                    |                                                               |                   |                         |
|--------------------|---------------------------------------------------------------|-------------------|-------------------------|
| Sampling start:    | 14-09-2026 kl.08:12                                           | Laboratory no.:   | DV26290312-001          |
| Sampler:           | Højvang/fko                                                   | <b>Sample ID:</b> | <b>1030</b>             |
| Analysis period:   | 14-09-2026 to 17-09-2026                                      | Packaging:        | OK                      |
| Sampling point:    | <b>Kamstrup industrivej 28 / 51.;</b>                         | Purpose:          | Operational control     |
| Sample type:       | <b>Process water (analyzed as drinking water)</b>             | Scope:            | Microbiological control |
| Withdrawal method: | Random sample                                                 |                   |                         |
| Sampling method:   | ISO 19458:2006 + MST Drikkevand. Manual for prøvetagning:2021 |                   |                         |

| Parameter                 | Result | Unit       | Min / Max. | DL | References                    | +/-         |
|---------------------------|--------|------------|------------|----|-------------------------------|-------------|
| Temperature               | 20,5   | °C         |            | 0  | SM 2550:2005, Felt            | s           |
| Pseudomonas aeruginosa    | 0      | CFU/100 mL | / 0        | 0  | ISO 16266:2008+MM0014^        | d 0,24 (lg) |
| Coliform bacteria         | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |
| Escherichia coli (E.coli) | 0      | MPN/100 mL | / < 0      | 0  | DS/EN ISO 9308-2:2014+MM0001^ | d 0,25 (lg) |

**Exceedances:** No exceedances, cf. the min. / Max. Values specified in the report

**Deviations / comments for this test:** None

## Location reference:

d) Højvang Laboratories A/S, Dianalund. DANAK no.: 428

The test results only apply to the tested items / subsets. Without the written permission of the laboratory, the report may only be reproduced in its entirety Højvang Laboratorier A/S disclaims any responsibility in connection with data provided by the requester.

Højvang Laboratorier A/S refuses to comment on attitudes and interpretations.

Analysis results are stated in the report with 2 significant digits unless otherwise agreed. When comparing with any limit and / or requirement value, the analysis result is used in the report.

Højvang Laboratorier A/S disclaims any responsibility in connection with the use of the stated minimum and maximum values or the use of the classifications made.

Made according to:

The sample has been taken in accordance with the current sampling plan / agreement.

## Approved by:



Heidi Jensen  
Laborant

## The report will be sent by email to:

vandanalysedk@kamstrup.com - Vandanalyser

Report status: Final

## Appendices for this report:

None

## Designations:

+/- expanded relative uncertainty in% with coverage factor 2. Results at the detection limit level are subject to a relatively greater measurement uncertainty than is generally the case.

\* Not accredited.

# Symbolizes that all components included in the sum in question have a concentration less than the detection limit of the individual component.

^ BEK no. 1275 of 31/10/2025 Executive Order on quality requirements for environmental measurements.

~ This is a translation of the Danish report with the same report number .