

Display user guide for Kamstrup OMNIPOWER electricity meter

Advanced 2 – Display configuration 131


OBIS code
Identification number.

Phase indication
L1 flashes when there is voltage on the phase.
The arrow indicates the present current direction.

Optical infrared eye
For reading and programming data.


SO diode
Flashes 1,000 times per kWh.
The display changes via the button – the change takes place upon button release.
Approx. 2 minutes after the last button press, the display changes automatically to the view 1.8.0 – accumulated electricity consumption in kWh.


Normal display




Accumulated active positive energy

Total electricity consumption from the electricity grid.
Measured in kilowatt hours [kWh].







Accumulated reactive negative energy R1
 Total reactive electricity production for the electricity grid.
 Measured in kilovolt ampere reactive hours [kvarh].




Accumulated reactive energy R1
 Total inductive reactive electricity consumption from the electricity grid.
 Measured in kilovolt ampere reactive hours [kvarh].




Accumulated reactive energy R2
 Total capacitive reactive electricity production for the electricity grid.
 Measured in kilovolt ampere reactive hours [kvarh].




Accumulated reactive energy R3
 Total inductive reactive electricity production for the electricity grid.
 Measured in kilovolt ampere reactive hours [kvarh].



Accumulated reactive energy R4
 Total capacitive reactive electricity consumption from the electricity grid.
 Measured in kilovolt ampere reactive hours [kvarh].




Actual active positive power
 Instantaneous electricity consumption from the electricity grid.
 Measured in kilowatt [kW].



Actual active negative power
 Instantaneous electricity production for the electricity grid.
 Measured in kilowatt [kW].




Active positive max power
 Highest electricity consumption from the electricity grid registered during the current debiting period.
 Measured in kilowatt [kW].




Time stamp for active negative max power
 Time stamp for the highest electricity production for the electricity grid registered during the current debiting period.




Active negative max power
 Highest electricity production for the electricity grid registered during the current debiting period.
 Measured in kilowatt [kW].




Time stamp for active negative max power
 Time stamp for the highest electricity production for the electricity grid registered during the current debiting period.




Actual voltage phase L1
 Measured in volts [V].




Actual current phase L1
 Measured in ampere [A].




Actual coefficient of performance phase L1




Date and time
 The display switches between the date and time in the meter.



Reserved for the utility



Display test
 All segments of the display turn on and off during this test.



Accumulated active positive energy
 Total electricity consumption from the electricity grid.
 Measured in kilowatt hours [kWh].