

Suspension for calculator

English

INSTALLATION





Kamstrup

Kamstrup A/S
Industrivej 28, Stilling, 8660 Skanderborg
TEL: 89 93 10 00 · FAX: 89 93 10 01
info@kamstrup.dk · www.kamstrup.dk


Appendix to MULTICAL® Installation Guide

If the installation is performed in humid environments, or if condensation might occur, the following must be observed:


1. Installation of calculator





Front, vertical




Front, at an angle
between horizontal
and vertical



Front, horizontal



Note! Cables **must** be installed from below.



Installation example with suspension.

Note: The suspension **must** not be used on condensing pipes.
Suspension kit item no. 5915-114.

3. Installation of temperature sensors

Temperature sensors must be mounted from below.

