

Display user guide for Kamstrup OMNIPOWER electricity meter

Advanced 1 – Display configuration 322


OBIS code
Identification number.

Phase indication
L1 flashes when there is voltage on the phase.
The arrow indicates the present current direction.

Optical infrared eye
For reading and programming data.

SO diode
Flashes 1,000 times per kWh.
The display changes via the button – the change takes place upon button release.
Approx. 2 minutes after the last button press, the display changes automatically to the view 1.8.0 – accumulated electricity consumption in kWh.


Normal display



Accumulated active positive energy


Total electricity consumption from the electricity grid.
Measured in kilowatt hours [kWh].

2




Accumulated active negative energy

Total electricity production for the electricity grid.
Measured in kilowatt hours [kWh].




Accumulated reactive positive energy

Total reactive electricity consumption from the electricity grid.
Measured in kilovolt ampere reactive hours [kvarh].




Accumulated reactive negative energy

Total reactive electricity production for the electricity grid.
Measured in kilovolt ampere reactive hours [kvarh].




Actual active positive power

Instantaneous electricity consumption from the electricity grid.
Measured in kilowatt [kW].



Actual active negative power

Instantaneous electricity production for the electricity grid.
Measured in kilowatt [kW].



Active positive max power

Highest electricity consumption from the electricity grid registered during the current debiting period.
Measured in kilowatt [kW].

2

<p>Time stamp for active positive max power Time stamp for the highest electricity consumption from the electricity grid registered during the current debiting period.</p>	<p>Active negative max power Highest electricity production for the electricity grid registered during the current debiting period. <i>Measured in kilowatt [kW].</i></p>	<p>Time stamp for active negative max power Time stamp for the highest electricity production for the electricity grid registered during the current debiting period.</p>

<p>Actual voltage phase L1 <i>Measured in volts [V].</i></p>	<p>Actual voltage phase L2 <i>Measured in volts [V].</i></p>	<p>Actual voltage phase L3 <i>Measured in volts [V].</i></p>

<p>Actual current phase L1 <i>Measured in ampere [A].</i></p>	<p>Actual current phase L2 <i>Measured in ampere [A].</i></p>	<p>Actual current phase L3 <i>Measured in ampere [A].</i></p>

<p>Actual coefficient of performance phase L1</p>	<p>Actual coefficient of performance phase L2</p>	<p>Actual coefficient of performance phase L3</p>

<p>Date and time The display switches between the date and time in the meter.</p>	<p>Manual control of breaker</p>	<p>Reserved for the utility</p>

<p>Display test All segments of the display turn on and off during this test.</p>	<p>Accumulated active positive energy Total electricity consumption from the electricity grid. <i>Measured in kilowatt hours [kWh].</i></p>